

ORDINANCE NO. 2022 - 15

TO PROVIDE A PROGRAM FOR PROTECTING THE PUBLIC WATER SYSTEM FROM CONTAMINATION DUE TO BACKFLOW OF CONTAMINANTS THROUGH THE WATER SERVICE CONNECTION INTO THE PUBLIC WATER SYSTEM

WHEREAS 675 IAC, Article 16, Rule 1.4, of the Indiana Plumbing Code, as adopted by the Indiana Fire Prevention and Building Safety Commission, requires protection of the public water supply from contaminants due to backflow through connections to fire protection and standpipe systems; and,

WHEREAS the Indiana Department of Environmental Management authorizes the maintenance of a continuing program of cross-connection control which will systematically and effectively prevent the contamination of all potable water systems;

NOW, THEREFORE, BE IT ORDAINED by the Town Council of the Town of Ferdinand of the State of Indiana:

SECTION 1. That a cross connection shall be defined as any physical connection or arrangement between any two otherwise separate systems, one of which contains potable water from the Town of Ferdinand water system, and the other, water from a private source, water of unknown or questionable safety, or steam, gases, or chemicals, whereby there may be a flow from one system to the other, the direction of flow depending on the pressure differential between the two systems.

SECTION 2. That no person, firm, or corporation shall establish or permit to be established or maintain or permit to be maintained any cross connection. No interconnection shall be established whereby potable water from a private, auxiliary, or emergency water supply other than the regular public water supply of Town of Ferdinand may enter the supply or distribution system of said municipality, unless such private, auxiliary, or emergency water supply and the method of connection and use of such supply shall have been approved by the Town of Ferdinand Water Utilities and by the Indiana Department of Environmental Management in accordance with 327 IAC 8- 10.

SECTION 3. That it shall be the duty of the IDEM Office of Water Quality to cause inspections to be made of all properties served by the public water system where cross connections with the public water system is deemed possible. The frequency of inspections and re-inspections based on potential health hazards involved shall be established by the IDEM Office of Water Quality.

SECTION 4. That upon presentation of credentials, the representative of the IDEM Office of Water Quality shall have the right to request entry at any reasonable time to

examine the property served by a connection to the public water system of the Town of Ferdinand for cross connections. On request, the owner, lessee, or occupant of any property so served shall furnish to the inspection agency any pertinent information regarding the piping system or systems on such property. The refusal of access or refusal of requested pertinent information shall be deemed evidence of the presence of cross connections.

SECTION 5. That the Town of Ferdinand Water Utilities is hereby authorized and directed to discontinue water service to any property wherein any connection in violation of this ordinance exists, and to take such other precautionary measures deemed necessary to eliminate any danger of contamination of the public water system. Water service shall be discontinued only after reasonable notice is served on the owner, lessee, or occupants of the property or premises where a violation is found or suspected to exist. Water service to such property shall not be restored until the cross connection(s) has been eliminated in compliance with the provisions of this ordinance.

SECTION 6. That, if it is deemed by the Town of Ferdinand Water Utilities that a cross connection or an emergency endangers public health, safety, or welfare and requires immediate action, and a written finding to that effect is filed with the clerk of the Town of Ferdinand and delivered to the consumer's premises, service may be immediately discontinued. The consumer shall have an opportunity for hearing within 10 days of such emergency discontinuance.

SECTION 7. That all consumers using toxic or hazardous liquids all hospitals, mortuaries, wastewater treatment plants, laboratories, and all other hazardous users install and maintain a reduced pressure principal backflow preventer in the main water line serving each building on the premises. The backflow preventer must be installed in an easily accessible location not subject to flooding or freezing.

SECTION 8. The reduced pressure principle backflow preventers shall not be installed below ground level.

SECTION 9. That this ordinance does not supersede the Indiana Plumbing Code, the IDEM Rule 327IAC 8-10 or any Town of Ferdinand plumbing ordinances, but is supplementary to them.

SECTION 10. In addition to IDEM Rule 327 IAC 8-10-4(c), the following customer facilities need a backflow prevention device:

MASTERBRAND 614 W 3RD ST
BENET HALL APARTMENTS 821 ALABAMA ST
SISTERS OF ST BENEDICT MONASTERY 802 E 10TH ST
YMCA 131 EAST 16TH ST
CASEYS GENERAL STORE 3504 2245 MAIN ST
FERDINAND FAMILY MEDICINE 115 SOUTH MAIN ST.
FERDINAND HEALTH CAMPUS SCENIC HILLS NH 710 ST BENEDICT DR
WENDY'S 480 SOUTH MAIN ST
TACO BELL 31692 420 SOUTH MAIN


**FERDINAND BIO SOLIDS FACILITY 10880 SOUTH 475 EAST
MCDONANDS 25 INDUSTRIAL PARK RD PO BOX 710
ARBYS 40 INDUSTRIAL ROAD
CIRCLE A FRENCH LICK PROPERTIES 460 MAIN ST**

SECTION 11. That if, in the judgment of the Superintendent of Water, an approved backflow prevention device is necessary for the safety of the public water system, the Superintendent of Water will give notice to the water consumer to install such an approved device immediately. The water consumer shall, at his own expenses, install such an approved device at a location and in a manner approved by the Superintendent of Water and shall have inspections and tests made of such approved devices as required by the Superintendent of Water and in accordance with the IDEM Rule 327 IAC 8-10.

SECTION 12. This ordinance shall become effective ten (10) days after adoption, the welfare of the Town of Ferdinand requiring it.

APPROVED THIS 17 DAY OF MAY, 2022


Kenneth J. Sigard


Ron Weyer


Debra Johnson


Tamara M. Miller, Clerk-Treasurer

Adopted: May 17, 2022
Effective: May 27, 2022
Published: May 25, 2022
Posted: May 18, 2022